Hi Jenn,

I will be requesting a waiver for a letter from the water district on the following grounds. Existing hook-up. 4 bedroom septic design supplied 460 gallons per day. Existing 3/4 line feed installed 25 years ago.3/4 line in Bowdoinham supplies 500 gallons of water an hour from Art McClain 5/18/2021. Possible water per year from existing line 4,380,000. The town of Bowdoinham per year 2,000,000 gallons of water. And the water district already supplied a letter stating its adequacy to supply on a previous application. Thank you, Scott

On Jun 1, 2021, at 2:43 PM, Jennifer Curtis <<u>planning@bowdoinham.com</u>> wrote:

Page 207 of Land Use Ordinance

12) Water Supply – a) If the project is to be served by a public water supply, the applicant must secure and submit a written statement from the supplier that the proposed water supply system conforms with its design and construction standards, will not result in an undue burden on the source or distribution system, and will be installed in a manner adequate to provide needed domestic and fire protection flows.

Jenn Curtis Director of Planning and Development Town of Bowdoinham (207) 666-5531 <u>planning@bowdoinham.com</u> <u>https://www.bowdoinham.com/</u>