

**From:** [Code Enforcement](#)  
**To:** [sammcoholdings@gmail.com](mailto:sammcoholdings@gmail.com)  
**Cc:** [Joshua Sammon](#); [Yvette Meunier](#)  
**Subject:** SammCo Holdings Conifer Ridge Development  
**Date:** Friday, August 23, 2024 8:48:48 AM

---

Good Morning Everyone,

I am following up on whether the Fire Marshall's Office is going to require a sprinkler system, and after talking with the Fire Marshall's Office this morning, they agree that a complete modular unit would not require a sprinkler system. I guess the Fire Marshall's Office did not understand from my first email that this project was utilizing modular construction. Ultimately, this is good news for the applicant because it could have been a hefty financial burden to install a sprinkler system.

Sorry for any confusion and feel free to contact me with any questions.

Sincerely,  
Jason

Jason Lorrain  
Code Enforcement Officer/LPI  
13 School Street  
Bowdoinham, ME 04008  
[ceo@bowdoinham.com](mailto:ceo@bowdoinham.com)  
207-666-5531